



East Side Fire District

20338 S Highway 97, Harrison, Idaho 83833-7773
Phone: 208.769.4269 | eastsidefire.lakeceda@gmail.com

Mobile Food Preparation Vehicle Safety Sheet

Business Name: _____ Owner/Operator: _____

Phone Number: _____ Address (Physical/Billing): _____

Dates: (start) _____ (end) _____ Location: _____

All **Mobile and Non-mobile concessions** must have a permit and approval from the Fire District.

\$45.00 for Single Inspection **\$80.00** Multiple Inspection (Make checks payable to East Side Fire)

Permits are subject to the latest edition of the appropriate city ordinance, IFC and IBC. The following is a brief synopsis of fire code requirements; additional requirements may be necessary based upon the event or location.

A map/sketch of the site shall be submitted and approved by the Fire District prior to the event. This map/sketch shall include the following: (1) Location of the Food Truck/Mobile Food Vendor; (2) 20' access to the Food Truck/Mobile Food Vendor and adjacent structures (this access shall be clearly marked and maintained throughout the event); (3) Clearance of at least 10' from all vegetation, landscaping and buildings; (4) All fire hydrants in the general area of operation. Proof of owner/agent agreement for the property use will also need to be included.

Fire extinguishers shall be installed, maintained, inspected, tested and tagged. Fire extinguishers shall be readily available and unobscured.

Date of last service: ABC _____ (2-A:10-B:C) Class K _____ (2.5 or 2- 1.5 gallon)

Where any cooking operation produces grease laden vapor or smoke, a Type I fire extinguishing hood system shall be installed. Service and cleaning will be required every 6 months.

- Date of last inspection and cleaning: _____
- Date of last service on the fire suppression system: _____
- Manual pull station unobstructed: YES NO

Propane Tanks: propane tanks for mobile food preparation vehicles shall be properly secured on the outside (not inside) of the vehicle and limited to no more than 200 water lbs.

- Hydro date clearly visible (not to exceed 10 years): YES NO
- Maintained in a clean and safe condition, and properly restrained to protect movement: YES NO
- Propane tanks for Mobile Food Vendors shall be located a minimum of 10 feet from any other vendor or property lines. Clearances may be reduced when approved by the Fire Department for special events.

Propane lines and fittings shall not leak. There shall be a bottle of soapy water available for Inspectors to conduct spray tests on all propane lines and fittings.

- Movement of appliances shall be limited by restraining devices installed in accordance with the connector and appliance manufacturers' instructions.

- A listed LP-gas alarm is installed within the vehicle in the vicinity of the LP-gas system components: YES NO
- Date of last fuel gas system inspection: _____
- Signs stating 'NO SMOKING WITHIN 25 FEET' posted on all propane tanks: YES NO

Electrical heating and cooking equipment shall comply with the NFPA 70 Electrical Code, International Mechanical Code and the International Fuel Gas code(s).

Fuel powered generators shall not produce offensive or visible exhaust. They shall be physically separated from people. Refueling must be completed before or after the event, when the engine is cool. NEVER WHILE THE GENERATOR IS RUNNING.

All generators and fuel cans shall be separated within ten (10) feet. All fuel cans onsite shall have a secure lid or cover to control vapor release.

Refueling shall occur outside a structure not less than 20' from the structure. The operator must protect the public from any fuel stored on site. The Fire District will approve the storage location.

Electrical cords shall not be subject to pedestrian or vehicle traffic and shall be a minimum 10-gauge wire. Electrical extension cords shall be in safe condition with no visible damage and be plugged into an approved receptacle.

Propane radiant heaters shall have a clearance of 5' from any building, structure or combustible materials. Clearance may be reduced if manufacturer's recommendation allows.

All tents, canopies or membrane structures used for motor vehicles, places of assembly or are an accessory to the mobile food preparation vehicle vendor event will require a separate Tent Permit. Also, outside cooking utilizing propane, wood or charcoal is not part of the mobile vendors permit agreement and is subject to additional regulations and fees. Contact the East Side Fire District at 208-769-4269 for these additional requirements and fees.

The East Side Fire District requires 48 hours' notice prior to the inspection process to complete the permit process.

THE ABOVE ITEMS MUST BE PHYSICALLY INSPECTED AND APPROVED BY EAST SIDE FIRE PERSONNEL PRIOR TO SUBMITTING THE PERMIT.

To the best of my knowledge, the information I provided is true and correct in compliance with the locally adopted codes and ordinances, the appropriate NFPA Standards, and the State of Idaho regulations.

REPRESENTATIVE SIGNATURE

DATE

EAST FIRE DISTRICT REPRESENTATIVE

INSPECTION DATE(S)

Current inspection year sticker affixed to mobile vendor

YES

NO